

**2015 Annual Drinking Water Report
Consumer Confidence Report (CCR)
Westwood North Water Supply Corporation
(936) 321-7766**

Annual water quality report for the period of January 1 to December 31, 2015

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (936)321-7766.

For more information regarding this report contact the Westwood North W.S.C. office at (936)321-7766 weekdays 8:00 AM to 5:00 PM.

Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on the susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessment and protection efforts at our system, contact the Westwood North W.S.C. office at (936) 321-7766.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://www.tceq.texas.gov/gis/swaview>

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
1-5703 Lotus Lane	5703 Lotus Lane	GW	Y	Chicot Aquifer
2-5703 Lotus Lane	5703 Lotus Lane	GW	Y	Chicot Aquifer
3-6310 Weisinger	6310 Weisinger	GW	Y	Chicot Aquifer
4-6310 Weisinger	6310 Weisinger	GW	Y	Chicot Aquifer

Water Quality Test Results:

Definitions: The following tables contain scientific terms and measures, some of which may require explanation

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which water system must follow.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable

pCi/L: picocuries per liter (a measure of radioactivity)

ppb: micrograms per liter (ug/L) or parts per billion – or one ounce in 7,350,000 gallons of water

ppm: parts per million or milligrams per liter (mg/L)

Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Chemical
2015	Chlorine	1.081	0.63	2.50	4.0	<4.0	ppm	Disinfectant used to control microbes

2015 Regulated Contaminants Detected

Lead and Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	#Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/24/2015	1.3	1.3	0.64	0	ppm	No	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems
Lead	09/24/2015	0	15	0	0	ppb	No	Corrosion of household plumbing systems; erosion of natural deposits

Regulated Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Sources of Contamination
Barium	07/23/2015	0.106	0.106 – 0.106	2	2	ppm	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	07/23/2015	0.19	0.16 – 0.19	4	4.0	ppm	N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum.
Nitrate (measured as Nitrogen)	07/23/2015	0.05	0.05 – 0.05	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Radioactive Contaminants

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Sources of Contamination
Combined Radium 226/228	07/23/2015	1.5	1.5 – 1.5	0	5	pCi/L	N	Erosion of natural deposits

Information about Secondary Contaminants

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary contaminants are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Information about Water Loss

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2015, our water system lost an estimated 2,055,636 gallons of water. If you have questions about the water loss audit, please call the water office at (936) 321-7766.

The Westwood North Water Supply Corporation Board of Directors meets on the 3rd Thursday of every month at the Corporation office (6310 Weisinger) at 7:00PM. The public is welcome to attend all Corporation meetings.